

# **Engine And Turbine Environmental Certification Workbook**

**For use with MassDEP's Environmental Results  
Program**

**Massachusetts Department of Environmental Protection**

# **THE ENVIRONMENTAL RESULTS PROGRAM**

## **INTRODUCTION**

The Massachusetts Environmental Results Program (ERP) is an on-going environmental performance enhancement and measurement initiative that seeks to cost-effectively improve the environmental performance of whole small business sectors. In this regulatory system, comprised of a unique set of linked regulatory tools, institutions and businesses are educated about their environmental impact and obligations, are required to self-evaluate and certify compliance, and are tracked to measure environmental performance changes. The Massachusetts Department of Environmental Protection (MassDEP) uses a statistical approach to track individual facility and whole-group performance results to identify poor performance areas and to effectively target limited agency compliance assistance and enforcement resources.

The ERP now includes performance standards that include the use of clean fuels, equipment maintenance, and record keeping requirements for new engines with a rated power output equal to or greater than 50 kilowatts (kW) and combustion turbines with a rated power output less than ten megawatts (MW). You must submit an initial installation certification that your facility meets environmental performance standards. By simplifying and clarifying the regulatory process, MassDEP hopes to reduce the cost and time required for compliance, while maintaining effective standards and improving environmental results. This workbook provides the information you must understand to meet your environmental obligations.

**6/2/06**

## **Table of Contents**

### **Getting Started**

- 1.1 Who is Subject**
- 1.2 Who Should Read This Workbook**
- 1.3 What You Should Know as a Facility Owner/Administrator**

### **Air Quality Requirements**

- 2.1 Emission Limits**
- 2.2 Fuel Requirements**
- 2.3 Operational Requirements**
- 2.4 Stack Design**
- 2.5 Sound**
- 2.6 Record Keeping**

### **Related Activities**

- 3.1 Underground Storage Tanks**

### **Definitions and Terms**

### **Appendix 1: Information Needed for Air Dispersion Modeling**

### **Appendix 2: MassDEP Regional Offices**

## **GETTING STARTED**

### **1.1 WHO IS SUBJECT TO ERP FOR ENGINE AND TURBINES?**

An owner or operator who installs, after March 23, 2006, an engine with a rated power output equal to or greater than 50 kW or a combustion turbine with a rated power output equal to or less than ten MW is subject to the requirements of the Environmental Results Program (ERP) for engines and turbines.

### **1.2 WHO SHOULD READ THIS WORKBOOK?**

#### Engine or Turbine Supplier/Installer:

All engines with a rated power output equal to or greater than 50 kW and combustion turbines with a rated power output equal to or less than one MW installed after March 23, 2006 must meet the air emission limits specified in the Engine and Combustion Turbine ERP regulation [310 CMR 7.26(43)] and outlined in this workbook. Therefore, it is crucial that you understand the requirements to ensure that the engine or turbine you install is capable of meeting the standards. You are also a primary source of technical expertise to your customers. Providing the information and service that your customer needs to operate and maintain the engine or turbine as efficiently and cleanly as possible not only minimizes emissions but is a good business practice as well. You are also responsible for supplying information to the owner/operator that each engine or turbine you supply/install complies with the applicable emission performance standards.

#### Facility Owner/Administrator:

As the owner or chief administrator of the facility, it is important that you understand the regulatory requirements described in this workbook. It is your responsibility to ensure that your new engine or turbine is operated in compliance with the applicable environmental regulations. By ensuring that the “hands-on” person who operates the engine or turbine understands the material in this workbook, you can make sure that the new engine or turbine is run cleanly and efficiently, with minimal impact to the environment. You will also be confident that the compliance certification you must sign is completed accurately and truthfully.

Under the heading "Related Activities", this workbook provides information you may need if underground petroleum storage tanks are located on your property.

### Engine or Turbine Operator:

As the operator, it is equally important that you understand the material in this workbook. You are the “hands-on” person who has the daily responsibility to operate and maintain the unit properly. To ensure compliance you must understand the fuel, stack, operational and record keeping requirements. You should also read the Related Activities section if you manage underground petroleum storage tanks.

## **1.3 WHAT YOU SHOULD KNOW AS A FACILITY OWNER / ADMINISTRATOR**

- The cornerstone of the Engine and Turbine ERP is the requirement that these engines comply with the applicable emission standards contained in the regulations at the time of installation. For example, a 500kW engine installed in 2006 must meet emission limitations for a model year 2006, 500kW engine.
- Particular care is required when locating engines and turbines so as not to cause a localized health or nuisance problem from emissions or sound impacts. The clean fuels requirement is a key component in assuring exhaust impacts are minimized from these units.
- The air contaminants emitted by engines and turbines can have significant health impacts, especially to the very young, the elderly, and the people suffering from respiratory illnesses. Particulate matter, especially the small-sized particulate matter generated by fuel combustion, can cause and contribute to serious respiratory problems. Sulfur dioxide ( $\text{SO}_2$ ) and oxides of nitrogen ( $\text{NO}_x$ ) are respiratory irritants and key ingredients in the formation of acid rain.  $\text{NO}_x$  is also a major contributor to summertime smog.
- There is no need to obtain a pre-construction plan approval under 310 CMR 7.02. Under ERP you submit a *certification* within 60 days following the start of engine or turbine operation. This allows you to quickly replace an old failing engine or turbine with a new unit that meets currently applicable standards for new units at the time of installation.
- If you identify compliance problems that cannot be corrected before submittal deadline, you must file a Return to Compliance Plan (RTC) for each of the problems along with your Compliance Certification. The RTC requires you to explain the problem, list the correction actions to be taken, and provide an anticipated return to compliance date. MassDEP may follow up with additional questions or an on-site inspection, if necessary.
- There is no fee associated with the certification. Please note that your facility still may be subject to other MassDEP fees, such as the annual air quality or hazardous waste compliance assurance fees.

- Installation of a new engine and turbine can have facility-wide ramifications. Potential emissions of the new engine and turbine may cause total emissions from your facility to exceed thresholds for other air pollution control requirements, including New Source Review (NSR), Operating Permits, and Prevention of Significant Deterioration (PSD).

If are or become a major source of air emissions you could be subject to one or more of the following:

- Operating Permit Program
- Emission Offsets and Non-attainment Review
- Prevention of Significant Deterioration requirements

If you have any questions concerning whether or not your facility is subject to any of these programs, please call your MassDEP Regional Service Center for additional information. Appendix 3 lists Massachusetts' cities and towns by region.

\*\*\*\*\*

Central Regional Office: (508) 792-7650

Northeast Regional Office: (978) 694-3200

Southeast Regional Office: (508) 946-2714

Western Regional Office: (413) 784-1100

\*\*\*\*\*

- You should also be aware that compliance with the requirements of engine and turbine ERP does not relieve you of the responsibility to comply with other regulations such as, federal 40 CFR 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines, which requires notification, record keeping, and reporting to the U.S. EPA. These rules were proposed on July 11, 2005. The EPA Customer Service Center may be called at (617) 918-1111 for further information.
- NOTIFICATION TO MassDEP IS REQUIRED within 60 days following the start of operation. Certification Forms are available through MassDEP's InfoLine at (617) 338-2255 or (800) 462-0444, or on our web site at [www.mass.gov/dep/service/online/erpforms.htm](http://www.mass.gov/dep/service/online/erpforms.htm)

The following sections describe the specific air quality and industrial wastewater requirements for emergency engines and emergency turbines.

## AIR QUALITY REQUIREMENTS

## 2.1 EMISSION LIMITS

The owner or operator must obtain from the supplier a completed Emission Limit Certification form, certifying that the engine or turbine as designed and installed will comply with the applicable emission limits for the lesser of the first three years or 15,000 hours of operation when operated according to the manufacturer's instructions. The emission limitations are set forth in the following tables:

Emission Limitations – Engines

Installation Date	Oxides of Nitrogen	Particulate Matter (Liquid Fuel <i>Only</i> )	Carbon Monoxide
On and after March 23, 2006	0.6 lbs/MWh	$\leq 1$ MW 0.7 lbs/MWh; $> 1$ MW 0.09 lbs/MW	10 lbs/MWh
On and after 1/1/08	0.3 lbs/MWh	0.07 lbs/MWh	2 lbs/MWh
On and after 1/1/12	0.15 lbs/MWh	0.03 lbs/MWh	1 lb/MWh

Emission Limitations – Turbines

Rated Power Output	Oxides of Nitrogen	Ammonia	Carbon Monoxide
Less than 1 MW	0.47 lbs/MW-hr Natural Gas	N/A	0.47 lbs/MW-hr Natural Gas
1 to 10 MW	0.14 lbs/MW-hr Natural Gas 0.34 lbs/MW-hr Oil	2.0 ppm at 15% O <sub>2</sub> dry basis	0.09 lbs/MW-hr Natural Gas 0.18 lbs/MW-hr Oil

Emission Limitations – Engines and Turbines

Installation Date	Carbon Dioxide
On and after March 23, 2006	1900 lbs/MWh
On and after 1/1/08	1900 lbs/MWh
On and after 1/1/12	1650 lbs/MWh

Visible emissions may not exceed 20% opacity at any time during emergency engine and emergency turbine operation. Visible emissions do not include water vapor.

## 2.2 FUEL REQUIREMENTS

To ensure efficient combustion and compliance with the emissions limitations, emergency engines and emergency turbines must be operated and maintained according to the manufacturer's instructions. On and after July 1, 2007, you shall not accept delivery for burning in your unit, fuel oil that does not conform to EPA's sulfur limits for transportation distillate fuel (15 parts per million (ppm) sulfur).

## 2.3 OPERATIONAL REQUIREMENTS

- Units shall be operated and maintained in accordance with the manufacturer's recommended operating and maintenance procedures.

## 2.4 STACK DESIGN REQUIREMENTS

The stack must discharge vertically upward. Stack heads, devices used to prevent precipitation from entering the stack, must not restrict the vertical flow of the exhaust gas stream. Devices such as "shanty caps" and "egg beaters" are prohibited. Coning of the top of the stack is acceptable. No more than a one-inch change in diameter to every five inches in length of cone is recommended in order to avoid serious backpressure that may affect air flow at the point of origin.

Stacks must be designed to minimize plume entrapment in wakes caused by obstructions to air streams.

- Care must be taken to locate units to avoid exhaust impacts upon people, windows and doors that open, fresh air intake, and other sensitive receptors.
- Units rated less than 300 kw shall have a minimum stack height of five feet above the facility roof-top or unit enclosure, whichever is lower.
- Units rated at 300kw but less than one megawatt shall have a minimum stack height of ten feet above the facility roof-top or unit enclosure which ever is lower. Again care must be taken to locate the unit to avoid exhaust impacts.
- For units rated at one megawatt and above, the minimum stack height must be 1.5 times the height of the building on which the stack is located. If the stack is less than 1.5 times the height of your building, or if any *adjacent structures* are taller than your stack (see *adjacent structure* in Definitions), air quality modeling must be performed

to document that the National Ambient Air Quality Standards (NAAQS) will not be exceeded. Appendix 1 lists the minimum data inputs that would be needed to execute an EPA Screen3 Model run. If you need assistance, call the BWP Air Planning & Evaluation Branch at 617-292-5766.

## **2.5 SOUND**

Another potential result of improper attention to locating your unit is the creation of a noise nuisance. Units should be housed in enclosures specifically designed to attenuate sound. Similar to exhaust impacts, locations that will impact people, such as locations near windows and doors that open, and other sensitive receptors are to be avoided.

## **2.6 RECORD KEEPING REQUIREMENTS**

The following records must be kept onsite for the life of the ERP engine and/or turbine.

- Information on the equipment type, make and model and rated power output.
- If applicable, the results of an air quality model run which demonstrates that emergency engine and/or emergency turbine emissions have not caused an exceedence of the National Ambient Air Quality Standards (NAAQS).
- Copies of certificates and documents from the manufacturer and supplier related to the certificates.

You must also keep the following records for at least three years. This means that each individual record must be retained onsite (or at the closest facility where records can be maintained) for three years from the date it was “created”.

- A monthly log of hours of operation, fuel type, and for fuel oil, heating value and sulfur content.
- Purchase orders, invoices, and other documents to substantiate information in the monthly log.

## **RELATED ACTIVITIES**

### **3.0 Underground petroleum storage tanks:**

Single wall, bare steel underground storage tanks containing petroleum products, including those resting on the ground, were required to meet leak detection and corrosion protection standards, or be replaced, as of December 22, 1998. For more information, contact your local fire Department.

\*\*\*\*\*

## DEFINITIONS AND TERMS

***Adjacent structure:*** means a structure that is within 5L of the stack. 5L means five times the lesser dimension (height or maximum horizontal width) of the structure.

***Air contaminant:*** volatile organic compounds (VOC's), sulfur dioxide (SO<sub>2</sub>), nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), and particulate matter are contaminants of concern in achieving air quality standards in the United States. Each geographic area is required to meet specific limits for each contaminant.

***Emission:*** any discharge or release of an air contaminant to the ambient air.

***Engines:*** spark ignition and compression ignition stationary reciprocating internal combustion engines.

***NAAQS (National Ambient Air Quality Standards):*** Massachusetts is subject to national standards that deal with six criteria pollutants: particulate matter (PM), nitrogen oxides (NO<sub>x</sub>), sulfur dioxide (SO<sub>2</sub>), ozone, carbon monoxide (CO) and lead.

***Natural Gas:*** a naturally occurring mixture of hydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane, or liquid petroleum gas (LPG), as defined by the American Society for Testing and Materials. LPG includes propane, butane, or a combination of propane and butane.

***Rated Power Output:*** the maximum electrical or equivalent mechanical power output stated on the nameplate affixed to the engine or turbine by the manufacturer.

***Source Registration/Emission Statement:*** Any person who operates a new emergency engine and emergency turbine subject to this ERP program is required to submit a Source Registration and Emission Statement, including BWP AQ AP-1 form to MASSDEP.

***Supplier:*** a person that manufactures, assembles, or otherwise supplies engines or turbines.

***Turbine:*** a stationary combustion turbine.

## **Appendix 1**

### **Minimum Data Inputs Required for an EPA Screen3 Model Run**

(For use in determining emission impacts upon ambient air quality – Section 2.4.)

1. Stack height (feet) =>
2. Stack inside diameter (feet) =>
3. Stack gas exit temperature (<sup>o</sup>F) =>
4. Stack flow rate (cubic feet per minute) =>
5. Building height (feet) =>
6. Minimum horizontal building width (feet) =>
7. \* Maximum horizontal building width (feet) =>
8. Type of fuel (natural gas or red dye distillate fuel oil) =>
9. Millions of Btu per hour of fuel input =>
10. Emission rate (grams per second) =>

\* Length of the diagonal line that bisects a building when viewing it from above.

## Appendix 2



### Massachusetts MassDEPartment of Environmental Protection

#### Addresses and Phone Numbers

**MASSDEP Boston**  
One Winter Street  
Boston, MA 02108  
Telephone: (617) 292-5500  
Fax: (617) 556-1049  
TDD: (617) 574-6868

**William X. Wall Experiment Station**  
37 Shattuck Street  
Lawrence, MA 01843  
Fax: (978) 688-0352  
*Division of Environmental Analysis*  
Telephone: (978) 682-5237 *Air Quality Surveillance*  
Telephone: (978) 975-1138

**Office of Watershed Management**  
627 Main Street  
Worcester, MA 01608  
Telephone: (508) 792-7470  
Fax: (508) 839-3469

**Millbury Training Center**  
Route 20  
Millbury, MA 01527  
Telephone: (508) 368-5600  
Fax: (508) 755-9253  
*Residuals Sludge Management*  
Telephone: (508) 368-5606  
*WWT Operator Certification*  
Telephone: (508) 368-5698

**MASSDEP Western Region**  
436 Dwight Street  
Suite 402  
Springfield, MA 01103  
Phone: (413) 784-1100  
Fax: (413) 784-1149



Adams  
Agawam  
Alford  
Athol  
Amherst  
Ashfield  
Becket  
Belchertown  
Bernardston  
Blandford  
Brimfield  
Buckland  
Charlemont  
Cheshire  
Chester  
Chesterfield  
Chicopee  
Clarksburg

Colrain  
Conway  
Cummington  
Dalton  
Deerfield  
Easthampton  
East Longmeadow  
Egremont  
Erving  
Florida  
Gill  
Goshen  
Granby  
Granville  
Great Barrington  
Greenfield  
Hadley

Hampden  
Hancock  
Hardwick  
Hatfield  
Hawley  
Heath  
Hinsdale  
Holland  
Holyoke  
Huntington  
Lanesborough  
Lee  
Lenox  
Leverett  
Leyden  
Longmeadow  
Ludlow  
Middlefield

Monroe  
Montague  
Monterey  
Montgomery  
Monson  
Mount Washington  
New Ashford  
New Marlborough  
New Salem  
North Adams  
Northampton  
Northfield  
Orange  
Otis  
Palmer  
Pelham  
Peru  
Petersham

Pittsfield  
Plainfield  
Richmond  
Royalston  
Rowe  
Russell  
Sandisfield  
Savoy  
Sheffield  
Shelburne  
Shutesbury  
Southampton  
South Hadley  
Southwick  
Springfield  
Stockbridge  
Sunderland  
Tolland

Tyringham  
Wales  
Ware  
Warwick  
Warren  
Washington  
Wendell  
Westfield  
Westhampton  
West Springfield  
West Stockbridge  
Whately  
Wilbraham  
Williamsburg  
Williamstown  
Windsor  
Worthington

**MASSDEP Central Region**  
627 Main Street  
Worcester, MA 01608  
Phone: (508) 792-7650  
Fax: (508) 792-7621



Action  
Ashburnham  
Ashby  
Auburn  
Ayer  
Barre  
Bellingham  
Berlin  
Blackstone  
Bolton  
Boxborough  
Boylston  
Brookfield

Charlton  
Clinton  
Douglas  
Dudley  
Dunstable  
East Brookfield  
Fitchburg  
Franklin  
Gardner  
Grafton  
Groton  
Harvard  
Holden  
Hopedale

Hopkinton  
Hubbardston  
Hudson  
Holliston  
Lancaster  
Leicester  
Leominster  
Littleton  
Lunenburg  
Marlborough  
Maynard  
Medway  
Medfield  
Mendon  
Milford

Millbury  
Millis  
Millville  
New Braintree  
Norfolk  
Northborough  
Northbridge  
North Brookfield  
Oakham  
Oxford  
Paxton  
Pepperell  
Phillipston  
Princeton

Rutland  
Shirley  
Shrewsbury  
Southborough  
Southbridge  
Spencer  
Sterling  
Stow  
Sturbridge  
Sutton  
Templeton  
Townsend  
Upton

Uxbridge  
Webster  
Westborough  
West Boylston  
West Brookfield  
Westminster  
Winchendon  
Worcester

**MASSDEP Southeast Region**  
20 Riverside Drive  
Lakeville, MA 02347  
Phone: (508) 946-2700  
Fax: (508) 947-6557



Abington  
Acushnet  
Attleboro  
Avon  
Barnstable  
Berkley  
Bourne  
Braintree  
Brewster  
Bridgewater  
Brockton  
Carver  
Canton  
Chatham  
Chilmark  
Cohasset

Dartmouth  
Dennis  
Dighton  
Duxbury  
Eastham  
East Bridgewater  
Easton  
Edgartown  
Fairhaven  
Fall River  
Falmouth  
Foxborough  
Franklin

Freetown  
Gay Head  
Gosnold  
Halifax  
Hanover  
Hanson  
Harwich  
Hingham  
Holbrook  
Hull  
Kingston  
Lakeville  
Mansfield  
Marion  
Marshfield  
Mashpee

Mattapoisett  
Middleborough  
Nantucket  
New Bedford  
North Attleborough  
Norton  
Norwell  
Norwood  
Oak Bluffs  
Orleans  
Pembroke  
Plainville  
Plymouth  
Plympton

Provincetown  
Randolph  
Raynham  
Rehoboth  
Rochester  
Rockland  
Sandwich  
Scituate  
Seekonk  
Sharon  
Somerset  
Stoughton  
Swansea  
Taunton

Tisbury  
Truro  
Walpole  
Wareham  
Wellfleet  
West Bridgewater  
Westport  
West Tisbury  
Weymouth  
Whitman  
Walpole  
Wrentham  
Yarmouth

**MASSDEP Northeast  
Region**

205 Lowell Street  
Wilmington, MA 01887  
Phone: (978) 694-3200



Amesbury  
Andover  
Arlington  
Ashland  
Bedford  
Belmont  
Beverly  
Billerica  
Boston  
Boxford  
Brookline  
Burlington  
Cambridge  
Carlisle

Chelmsford  
Chelsea  
Concord  
Danvers  
Dedham  
Dover  
Dracut  
Essex  
Everett  
Framingham  
Georgetown  
Gloucester  
Groveland  
Hamilton  
Haverhill

Ipswich  
Lawrence  
Lexington  
Lincoln  
Lowell  
Lynn  
Lynnfield  
Malden  
Manchester-By-The-Sea  
Marblehead  
Medford  
Melrose

Merrimac  
Methuen  
Middleton  
Milton  
Nahant  
Natick  
Needham  
Newbury  
Newburyport  
Newton  
  
North Andover  
North Reading  
Peabody

Quincy  
Reading  
Revere  
Rockport  
Rowley  
Salem  
Salisbury  
Saugus  
Sherborn  
Somerville  
Stoneham  
Sudbury  
Swampscott  
Tewksbury  
Topsfield  
Tyngsborough

Wakefield  
Waltham  
Watertown  
Wayland  
Wellesley  
Wenham  
Westford  
West Newbury  
Weston  
Westwood  
Wilmington  
Winchester  
Winthrop  
Woburn